

To: All Contractors

Re: Clarification on Procurement Reference No.: ICB/001/2009

Reference is made to the bid for the Construction of Adigrat University G+8 Central Administration Building announced under Procurement Reference No.: ICB/001/2009.

Accordingly we would like to give Clarifications for the bid as stipulated below:

I. Clarification on Furniture Supply and Works

- The brand, production and origin of all the works grouped under Furniture shall be Europe, preferably Italy.

II. Clarification on Aluminum and Glazing

- The sub-division of all the spider curtain wall can be revised as deemed necessary and practical by the bidder/ corresponding supplier subject to approval of the Engineer/ Architect and the glazing type for the spider curtain wall shall be Tempered Glass with 10mm thickness.
- The sub-division of all the curtain wall can be revised as deemed necessary and practical by the bidder (corresponding supplier) subject to approval of the Engineer/ Architect and the glazing for the curtain wall shall be Double Glazed with Non-Reflective Glass of 6mm thickness (which means 6mm glass + 20mm vacuum + 6mm glass). The opening direction shall be outward.
- The bidder shall develop the size and extent of the Skylight Roof Cover form the provided Plans, Elevations, Sections and any similar and relevant details subject to approval of the Engineer/ Architect.
- The size and quantity of Guard Rails for Staircases and Terraces shall be taken from the provided drawings (Plans, Elevations, Sections and any similar and relevant details) subject to approval of the Engineer/ Architect.

III. Clarification on Electrical Installation

- We would like to give clarification and amendment on some items of Electrical Installation as per the attached sheet.

